



---

## **SAV Model LD Gate Valves**

### **AWWA C515 Certificate of Compliance**

This letter is to certify that all 18-inch through 24-inch Model LD, NRS resilient wedge gate valves manufactured by Steel Arch Valves Company in Kansas City, Kansas, meet or exceed the standards established by AWWA for Resilient Seated Gate Valves; ANSI/AWWA C515.

The valves are rated by Steel Arch Valves Co. for a working pressure of 250 psi. Each valve is shell tested to 500 psi and tested for complete operation at 250 psi and 25 psi before shipment.

In addition, all Steel Arch Valves gate valves have a 10 year limited warranty against manufacturing and material defects from the date of purchase.

If you have any questions or need further information, please feel free to contact us.

On behalf of Steel Arch Valves,

A handwritten signature in black ink, appearing to read 'John Wilber', is positioned above the printed name.

John Wilber

VP Engineering  
Steel Arch Valves Company

---

**Steel Arch Valves Company**

An ISO 9001 and ISO 14001 registered company

© Copyright SAV Group.

**Expect... SAV**